

ManageUPS® NET ADAPTER P-Series

ManageUPS® NET ADAPTER VP

ManageUPS® DCU DISCOVERY AND CONFIGURATION UTILITY





Quick Start Guide

© 2018 AMETEK Electronic Systems Protection | Technical Support 1-800-645-9721 | surgex.com | QS-UPS-SNMP-Rev-A

BEFORE YOU BEGIN

Internal ManageUPS adapters are powered from within the chassis of the UPS. For these adapter models, hardware installation must be completed before network and service settings can be configured in the adapter.

If an external ManageUPS adapter is powered up, it will function on a network even if it is not connected to a UPS.

In either case, there may be installation details specific to the particular UPS model family you are working with.

Review the *Supplemental Installation Note* that covers the specific UPS model you are working with before installing and configuring your ManageUPS adapter.

MANAGEUPS QUICK START GUIDE

Key Topics

The Quick Start Guide covers key topics at a minimal level of detail:

- 1. Configuring essential network settings
- 2. Configuring optional settings for various services
- 3. Applying option settings to multiple adapters
 - 4. Using Filtered View

If you are installing a ManageUPS P-Series model, see section VII in the **User Guide and Reference** document for information on connecting the Environment Sensor to the ManageUPS Blue Bus connector.

If you need more information on any of the subject areas, try using the help resources provided in the ManageUPS WEB interface via the "?" link.

ManageUPSNET	· ·		PowerVAR Home Connectivity Solutions
Network Adapter 10.201.100.19	3200 Series >> Status		Refre h ?
@?	Dattery Status		
- 3200 Series	Battery Status: Battery Charge Remaining: Battery Voltage:	Normal 100 %	/
Status Control	Internal Temperature: Est. Battery Life:	27 C, 80 F 54 Minutes	

Further detail is also provided in the full **User Guide and Reference** document located at <u>http://connectivity.SurgeX.com</u>.

Deploy First?	After you review this Quick Start Guide , you will realize that ManageUPS can be configured in a configuration lab and then deployed to a live network [] or can be
Configure First?	deployed first and configured later.
Your choice.	Generally, if your network does not use DHCP, and you need to deploy ManageUPS on a different network than the one that your workstation is connected to, you will need to configure ManageUPS first on a local network.



Windows Workstation?

ManageUPS DCU Discovery and Configuration Utility The easiest way to get started is to use the *ManageUPS DCU* application from a Windows workstation connected to the same local network that ManageUPS is also connected.

To use this method, install ManageUPS DCU from the website.

Connect the ManageUPS adapter to the network. (see diagrams on pages 3 and 4)



ManageUPS DCU helps simplify initial configuration and ongoing management of ManageUPS adapters.

DCU installs on a Windows computer.





Deploy First?

The simplified networking functions of ManageUPS adapters and DCU allow you to deploy adapters to remote locations first and configure them later via the network link.

AUTO-FIND ZONE:

ManageUPS VP & ManageUPS P-Series adapters will present themselves to ManageUPS DCU automatically on the *local network*.

SEARCH ZONE:

DCU has an efficient search mechanism that can be used to locate ManageUPS adapters connected to other networks.

To find adapters in the search zone, adapters must have valid IP addresses. Valid IP addresses may be assigned automatically by DHCP, or could be static IP addresses configured prior to deployment.



NOTE: If there is no DHCP server on the network that ManageUPS is connected to, ManageUPS will negotiate an IP address from the range reserved for Link-Local networking (169.254.xxx.xxx).

DCU will automatically add the link-local route to your Windows workstation in order to discover and connect to adapters connected to the local network. You must run DCU from a user account with Administrator rights.

However, link-local addresses are non-routable. DCU will not be able to find adapters on other networks (SEARCH ZONE) that have assumed link-local addresses.



Configure First?	Configure first in a staging location and then deploy		
	Set up a simple configuration lab using an Ethernet crossover cable between		

ManageUPS and your DCU workstation's Ethernet adapter[®] or use a hub to create a stand-alone network.



NOTE: If there is no DHCP server on your Local network, ManageUPS will negotiate an IP address from the range reserved for Link-Local networking (169.254.xxx.xxx).

DCU will automatically add the link-local route to your Windows workstation in order to discover and connect to adapters connected to the local network. You must run DCU from a user account with Administrator rights.





Starting ManageUPS DCU



Navigation and Organization tools

If there are no ManageUPS adapters on the same network as your DCU workstation, the *NAVIGATION PANE* will be empty as shown below.

Adapters on the local network will appear in the *Local Network* tree (see inset) until you move the icon into the *Bookmarks* tree.

Left mouse-click either tree icon to bring a description of the navigation mechanism and display options to the *MAIN WINDOW*.

To find adapters on another network, left-mouse-click the Search tool icon on the toolbar to open the IP-range search dialog. Search results will appear in the Bookmarks tree.



Left mouse-click the "+" to the left of an adapter icon to open the configuration navigation tree for that adapter.



Configuring Essential Network Settings The default ManageUPS network configuration mode accepts settings provided automatically by a DHCP server connected to the same network.

The first question to answer is whether ManageUPS will keep DHCP settings or will need fixed or "*static*" IP settings. Discuss this with the network administrator if you are not familiar with the network policy.

For more information on setting network parameters, use the ? help on the ManageUPS network settings WEB page or see **Section II: Network Setup** in the full **User Guide and Reference**.



To access the dialog page for entering manual IP settings, select Statically from the drop down list box and press the APPLY button.

nter Netv	work Passwo	rd	<u>? ×</u>
? >	Please type y	our user name and password.	
8	Site:	192.168.1.209	
	Realm	ManageUPSnet Web Server	
	<u>U</u> ser Name	admin admin	
	Password	***** admin	
	□ <u>S</u> ave this	password in your password list	
		OK Ca	ncel

Before you can access ManageUPS, you will need to enter the User Name and Password combination.

The default entries are shown above.

You can change these later in the Security>>Passwords dialog area.



Configuring Service options



ManageUPS net adapter provides a variety of monitoring and management-related services for Uninterruptible Power Systems and associated auxiliary systems.

Navigation to the specific ManageUPS WEB pages that will be used to configure service options is simplified in the expanded device tree in the DCU navigation pane (left).

To become more familiar with these services and how to use them, refer to **Section I: About ManageUPS** and **Section III, Setting Service Options** in the full **User Guide and Reference** document.

Some services require resources that are considered generally available on most networks. The table below identifies key variables and other considerations for each service.

Service	Key Resources or Parameters	
Event/Alarm messaging via Email	E-mail destinations the email addresses of where to send event/alarm messages SMTP Server: DNS Name or IP address of SMTP server on the network that ManageUPS will use to route email.	
Data and/or Event Logging	NTP (Time) Server The default time reference for stamping log file entries is a time- server on the internet. If ManageUPS will not have internet access from the network it is connected to, ask your network administrator for the IP address or DNS name of a timeserver on your network.	
Remote Shutdown (Network Shutdown) Controller	Shutdown Targets / Schedules / Delays DNS names or IP address/range of servers or workstations on the network to be shutdown by ManageUPS in the event of extended AC outages Shutdown targets will need software (safe shutdown agent) installed that is compatible with ManageUPS. Some shutdown agents may require authentication credentials. You may also want to consider timing delays for various groups of servers or workstations.	
SNMP	SNMP trap destinations: (IP addresses) SNMP communities: (names, IP range and rights)	
Security	 HTTP, Telnet, FTP servers are active and use well- known ports by default. User Access settings determine read/write privileges and access password. See Section VI, Administrative Settings in the full User Guide and Reference document 	



Applying Service Option settings to multiple adapters Once you have configured one adapter with SNMP, email or other service options, you can download the configuration file from the first adapter and upload it to other adapters.

To access the download dialog, press the download button tool bar.



💐 ManageUPS DC	U				
Eile Help					
3 + X	*	û 🖑	B 33	30	🖉 🔇

SNMP settings are held in a file named snmp.conf

All other service options are held in a file named mopups.cfg

manageups dcu		
Step 1 Select file to download.	Look jn: 🔄 DCU/myfiles/ 💌 🗲	E 🕈 🏢 🏢
mopups.cfg 🗾	reboot.txt	
Step 2		
Enter FTP user name and password.		
User:		
Password		
kange as		
Step 3		
Select local destination ->		0.000
Step 4	File <u>n</u> ame:	<u>S</u> ave
Select file name to save as - >	File type: All Files (*)	Cancel
		-

To access the upload dialog, press the upload button i on the tool bar.

Use the File button to access the file directory. Select the file you want to upload. Check the adapters in the Targets list that should receive the file. Check Reboot after upload. Press the Upload button.

Upload File Choose File: C://update-3.00.04	1028.tar	? ×
Targets	Status	
🗹 🍺 New Name	Validating MD5 signature 50% comp	lete. 🔿
🗹 🍺 New Name	Updating MUN Firmware 6% comple	te. 🔾
🗹 🍺 New Name	Upload Successful	ं
	🔽 Reboot after upload Uncheck All	Upload

The Upload utility can also be used to update adapter firmware as well as upload settings and configuration files.

Press the upload log view button on the DCU toolbar to view upload history.

See Section VI, Administrative Settings in the full User Guide and Reference document for more information on file function and maintenance



Filter View creates a list of adapters in the *Bookmarks* tree that meet the filter criteria.

This can be useful in identifying new versus legacy ManageUPS adapters in a mixed population, or for identifying adapters that may not have the latest firmware or service option settings files.

Use the filter tool in the DCU toolbar to access the filter dialog.

Select the type of adapter and/or upload file name and the upload date and press OK.

😵 New Filter		<u>?</u> ×
Show all		
ManageUPS	S Net Legacy Adapte	ers
ManageUPS	6 Net Adapters	
where file	mopups.cfg	•
has not been	updated since	03/01/2005 🚔
	ОК	Cancel

Access the filtered list result using the folder tab that appears at the bottom of the *Navigation Pane*.

All Filtered List	
Done	